



FOR SEALS AND SIGNATURES SEE ORIGINAL DRAWINGS DATED NOVEMBER 2013

NO.	DATE	BY	CHKD	REVISION	APVD
2	01/2014			CONFIRMED	
1	11/2013			ADDENDUM 1	

KODIAK ISLAND BOROUGH
 KODIAK LANDFILL
 LATERAL EXPANSION PHASE 3
 LEACHATE TREATMENT PLANT
 KODIAK ISLAND, ALASKA

CH2MHILL
 LEACHATE TREATMENT PLANT
 MECHANICAL PLAN

DATE	JANUARY 2014
PROJ	354650
DWG	020-M-2000
SHEET	69 of 100

PLAN
 3/16"=1'-0"

- NOTE:**
- CHEM PIPING FROM THIS POINT TO SOURCE IS DOUBLE CONTAINED
 - PROVIDE FRP SLEEVE ATTACHED TO COVER AND SEAL AROUND SST EXHAUST DUCT W/ MODULAR MECHANICAL SEAL. TYP ALL PIPE PENETRATIONS THRU COVER. COORDINATE ALL PENETRATIONS ON FRP COVERS W/ MANUFACTURER.
 - INSTALL 316 DEFLECTOR PLATE OR PVC TURNDOWN PIPE. COORDINATE WITH ENGINEER AND SHOP DRAWINGS WITH CASSETTE TO ENSURE CASSETTE CAN BE LIFTED WITHOUT INTERFERENCE.
 - 22LCP01 NOT SHOWN. COORDINATE WITH THE BELT FILTER PRESS APPROVED SHOP DRAWINGS.

REUSE OF DOCUMENTS: THIS DOCUMENT, AND THE IDEAS AND DESIGNS INCORPORATED HEREIN, AS AN INSTRUMENT OF PROFESSIONAL SERVICE, IS THE PROPERTY OF CH2MHILL AND IS NOT TO BE USED, IN WHOLE OR IN PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF CH2MHILL. ©CH2MHILL 2012. ALL RIGHTS RESERVED.
 CONFORMED DRAWING JANUARY 14, 2014